

Appendix C
COMPLIANCE ASSURANCE MONITORING PLAN

This page intentionally left blank.

**Compliance Assurance Monitoring Plan
Middletown Coke Company**

Background

Emission Unit

Description: Spray Dryer Baghouse Flue Gas Desulfurization (FGD) System

Operation Identification: FGD System

Facility: Middletown Coke Company, Butler County, Ohio

Applicable Regulation and Emission Limit

Regulation Number: None

Pollutant: SO₂ and PM/PM₁₀

Emission limits:

Annual Average SO₂ Limit – 1091 tons/yr

Monthly Average SO₂ Limit – 249 lbs/hr

Monthly Average PM/PM₁₀ Limit – 30 lb/hour

Annual Average PM/PM₁₀ Limit – 131 tons/year

Applicable Monitoring Requirements

None. Propose to use procedures in 40 CFR 60, Appendix B.

Control Technology

Spray Dryer

Pulse Jet Baghouse operated under negative pressure

Monitoring Approach

	Indicator No. 1	Indicator No. 2
I. Indicator Measurement Approach	SO ₂ Concentration SO ₂ concentration is measured with a CEMS meeting: 1. 40 CFR 60 Appendix B, Performance Specification (PS): • PS2 – Specification for SO ₂ CEMS in Stationary Sources 2. 40 CFR 60, Appendix F: Quality Assurance Procedures.	Pressure Drop Pressure drop across the baghouse is measured continuously by using a magnahelic gage or pressure transducer.
II. Indicator Range	An excursion is defined as monthly average greater than 249 lbs SO ₂ /hr; excursions trigger an inspection, corrective action, and reporting, requirement. SO ₂ range (0-200 ppm) Flow Rate range (0-100 ft/sec)	An excursion is defined as a pressure drop greater than 12 or less than 3 in. H ₂ O. Excursion triggers an inspection, corrective action, and reporting, requirement.
III. Performance Criteria A. Data Representativeness	Probes will be located as described in Performance Specification 2. Representativeness validated by RATA testing.	Pressure taps will be located in the baghouse inlet and outlet plenums to measure overall pressure drop. The gage will have a minimum accuracy of 0.5 in H ₂ O.
B. Verification of Operational Status	Daily calibration and observation	Recorded each day

	Indicator No. 1	Indicator No. 2
C. QA/QC Practices and Criteria	<ol style="list-style-type: none"> 1. Daily Calibration Drift (CD) evaluation (with instrument being adjusted whenever the daily CD exceeds 10% range) 2. Quarterly Cylinder Gas Audit (CGA) 3. Annual Relative Accuracy Test Audit (RATA) 4. Maintenance according to manufacturer's specifications 	<p>Calibrate the pressure gage annually.</p> <p>Maintenance according to manufacturer's specifications.</p>
D. Monitoring Frequency	Continuous	Continuous
E. Data Collection Procedures	SO ₂ concentration, flow rate, and mass emission rate recorded automatically in a data acquisition system (DAS).	Record pressure drop every day.
F. Averaging Period	Monthly and annual	None

I. Rationale for Selection

Procedures in EPA Performance Specifications, as the basis for NSPS monitoring, are generally acceptable for non-NSPS applications.

Pressure drop is an appropriate indicator of baghouse performance as described in the EPA CAM Technical Guidance Document.

II. References

1. 40 CFR 60 Appendix B, Performance Specification (PS):
 - PS2- Specification for SO₂ CEMS in Stationary Sources
2. 40 CFR 60, Appendix F: Quality Assurance Procedures
3. U.S. EPA Office of Air Quality Planning and Standards Emission Measurements Center, *Technical Guidance Document: Compliance Assurance Monitoring, Revised Draft*, August 1998.