

3745-65-35 Required aisle space.

The owner or operator shall maintain aisle space to allow the unobstructed movement of personnel, fire protection equipment, spill control equipment, and decontamination equipment to any area of facility operation in an emergency, unless aisle space is not needed for any of the above-mentioned purposes.

Effective: 01/07/1983

119.032 review dates: Exempt

Promulgated under: 119.03

Statutory authority: 3734.12

Rule amplifies: 3734.12

Prior effective dates: 04/15/1981