

**3745-66-94 General operating requirements.**

- (A) Hazardous wastes or treatment reagents shall not be placed in a tank system if they could cause the tank, its ancillary equipment, or the secondary containment system to rupture, leak, corrode, or otherwise fail.
- (B) The owner or operator shall use appropriate controls and practices to prevent spills and overflows from tank or secondary containment systems. These include at a minimum:
  - (1) Spill prevention controls (e.g., check valves, dry disconnect couplings);
  - (2) Overfill prevention controls (e.g., level sensing devices, high level alarms, automatic feed cutoff, or bypass to a standby tank); and
  - (3) Maintenance of sufficient freeboard in uncovered tanks to prevent overtopping by wave or wind action or by precipitation.
- (C) The owner or operator shall comply with the requirements of 3745-66-96 of the Administrative Code if a leak or spill occurs in the tank system.

Effective: 09/02/1997

119.032 Review dates: Exempt

Promulgated under: 119.03

Statutory authority: 3734.05, 3734.12

Rule amplifies: 3734.05, 3734.12

Prior effective dates: 04/15/1981, 01/07/1983, 12/08/1988